



Memo

To:	Senior Manager: Land Development Management For attention: H Strijdom/C van der Bank/E Cyster
From:	Manager: Planning and Customer Services
Enquiries:	L Laing
Reference number:	13004
Date:	15 March 2023
Subject:	APPLICATION FOR CONSENT USE FOR VISITORS' ACCOMMODATION, ERF 13004, PAARL

Time Limit on Conditions: These conditions will be limited to a period of one (1) year from the date as on the covering memo from this department. After this period a re-application must be submitted for approval by this department.

1. INFORMATION REQUIRED/OUTSTANDING

1.1. None.

2. THE FOLLOWING CONDITIONS WILL APPLY

- 2.1. Only one service cable connection per erf is allowed.
- 2.2. No trees or any type of structures may be erected under or near any new or existing electrical infrastructure.
- 2.3. All electrical equipment shall comply with Drakenstein Municipality standards and have twenty-four-hour access for maintenance purposes.
- 2.4. A service level agreement between the municipality and the owner or developer of the development must be arranged at Electro-Technical department (Planning and Design division - Chief Engineering Technician) for any requirement to increase the existing supply to the premises.

3. GENERAL

- 3.1. NRS069 Network recovery cost will apply for any additional load requirement for this development and will be calculated according to the following as indicated in approved tariffs: **R 4 500.11 x per kVA (V.A.T. included)**. The cost as mentioned above is valid until 30 June 2023 and will escalate thereafter for each upcoming financial year which is between 1 July and 30 June.
- 3.2. The developer will be responsible to carry all cost of the electrical installation including the linkage to the infrastructure as determined by the Manager: Planning and Customer Services.
- 3.3. All upgrade and service costs must be paid at the finance section in cash before any service connection may be rendered.

A private registered installation electrician shall be used to do all installations and alterations according to SANS 10142, Occupational Health and Safety Act (Act 85 of 1993) and Drakenstein Municipal By-laws, prior to the proposed development.

A certificate of compliance and occupational certificate must be handed over to the Electro-Technical Services Department (Service section) on the day the service is render, or the case may be.

The Manager: Planning and Customer Services with reference to the services and conditions has no objection to this application.

Yours faithfully

L LAING
MANAGER: PLANNING AND CUSTOMER SERVICES
I:\BEPLAN_3\Sub_Divisions_Rezoning\202223\13004