

Memo

To:	Senior Manager: Land Development Management For attention: H Strijdom/C van der Bank/E Cyster
From:	Manager: Planning and Customer Services
Enquiries:	L Laing
Reference number:	8/2/5_5800
Date:	30 June 2024
Subject:	PROPOSED SUBDIVISION, A PORTION OF THE REMAINDER OF ERF 5800, WELLINGTON

Time Limit on Conditions: These conditions will be limited to a period of one (1) year from the date as on the covering memo from this department. After this period a re-application must be submitted for approval by this department.

1. INFORMATION REQUIRED/OUTSTANDING

1.1. None.

2. THE FOLLOWING CONDITIONS WILL APPLY


- 2.1. The 11kV distribution network requires excessive upgrading which includes constructing a 11kV switching station in close proximity of the proposed subdivision.
- 2.2. An application must be submitted to Eskom to upgrade the existing notified maximum demand.
- 2.3. Only one service cable connection per erf is allowed.
- 2.4. No trees or any type of structures may be erected under or near any new or existing electrical infrastructure.
- 2.5. All electrical equipment shall comply with Drakenstein Municipality standards and have twenty-four-hour access for maintenance purposes.
- 2.6. The developer will be responsible for all cost in the case where he or she request any infrastructure situated in the road reserve to be moved or relocated to new proposed positions.
- 2.7. The developer is required to include measures to improve energy efficiency for any additional load requirement to the existing electrical supply.
- 2.8. It may be requested to register service servitudes where existing and or new infrastructure will or have been installed.

2.9. A service level agreement between the municipality and the owner or developer of above-mentioned erf must be arranged at Electro-Technical Service Department (Planning and Design division - Chief Engineering Technician) in the case where a request for the change and or upgrade of the existing supply is required.

3. GENERAL

- 3.1. NRS069 Network recovery cost will apply and will be calculated according to the following as indicated in approved tariffs: **R5 123.00 per KVA (V.A.T. included)**. The cost as mentioned above is valid until 30 June 2024 and will escalate thereafter for each upcoming financial year which is between 1 July and 30 June.
- 3.2. The developer will be responsible to carry all cost of the electrical installation.
- 3.3. All upgrade and service costs must be paid at the finance section in cash before any service connection may be rendered.
- 3.4. A private registered electrical installation electrician shall be used to do all installations and alterations according to SANS 10142, Occupational Health and Safety Act (Act 85 of 1993) and Drakenstein Municipal by-laws prior to the development.
- 3.5. A certificate of compliance and occupational certificate must be handed over to the Electro-Technical Services Department (Service section) on the day the service is rendered or as the case may be.
- 3.6. The Manager: Planning and Customer Services with reference to the services and conditions has no objection to this application.

Yours faithfully

A handwritten signature in black ink, consisting of a large, loopy 'L' followed by a horizontal stroke and a large oval loop.

L LAING

MANAGER: PLANNING AND CUSTOMER SERVICES

I:\BEPLAN_3\Sub_Divisions_Rezoning\202324\5800